

CARROLL COUNTY VEHICLE FUELING FACILITY

.....

The Carroll County Board of Commissioners submits Addendum 2 to Solicitation No. 10-A002, **CARROLL COUNTY VEHICLE FUELING FACILITY**. In an effort to clarify Specifications, Conditions and Terms the following changes or additions are made to the original Request for Proposal (RFP).

I. GENERAL CHANGES AND ADDITIONS TO ORIGINAL SOLICITATION

1. Electrical Panel for Fuel Island-

- Bidder will be required to install a 200 amp panel for Fuel Island.
- Bidder will be required to install separate 8 pole lighting contacts, individual powered breakers neutral switch, 3 each 30 amp double pole and 10 each 20 amp single pole. All of this to be the same phase.

All other Specifications, Terms and Conditions, not affected by the above changes and additions, remain in effect.

Bidders shall indicate in their proposals they have received this addendum (Addendum 2), **CARROLL COUNTY VEHICLE FUELING FACILITY** (Solicitation 10-A002). Proposals without this acknowledgement may be rejected.

T. Loftin
Purchasing Clerk
(770) 830-5804
tloftin@carrollcountyga.com