

## Addendum No. 3

Carroll County Business Park Phase 2  
Solicitation Number 10-A018  
Carroll County Board of Commissioners

June 24, 2010

Addendum No. 3 consists of two (2) Printed (8½" x 11") Pages;

Addendum No. 3 consists of clarifications, changes, modifications and/or revisions to the Specifications dated April 2, 2010, by Georgia and West, Inc. and are hereby made a part of the Contract Documents.

### **ADDITION TO SPECIFICATIONS:**

#### **DIVISION 3 PRELIMINARY BRIDGE SPECIFICATIONS FOR BIDDING PURPOSES ONLY**

1. Add the following pre-approved bridge supplier as an equal:

Signature Bridge, Inc.  
8500 Station Street, Suite 280  
Mentor, OH 44060  
Phone: (800) 409-8070  
Fax: (440) 205-2989  
E-mail: [stacy.elmouhawesse@signaturebridge.com](mailto:stacy.elmouhawesse@signaturebridge.com)

2. Add the following Warranty Maintenance Program requirements to the Bridge Contractor's responsibility during the first calendar year following acceptance of the bridges.

A) At 90 days: Perform all recommended maintenance as specified in the Manufacturer's Warranty, including but not limited to inspecting, cleaning, tightening all fasteners and hardware, coating, sealing and repairing defective material.

B) At 180 days: Perform all recommended maintenance as specified in the Manufacturer's Warranty, including but not limited

Georgia and West, Inc.  
105 Corporate Drive  
Carrollton, GA 30117  
Phone: 770-834-4694  
Fax: 770-834-1005  
E-mail: [mailbox@georgiaandwest.com](mailto:mailbox@georgiaandwest.com)

to inspecting, cleaning, tightening all fasteners and hardware, coating, sealing and repairing defective material.

C) At 360 days: Perform all recommended maintenance as specified in the Manufacturer's Warranty, including but not limited to inspecting, cleaning, tightening all fasteners and hardware, coating, sealing and repairing defective material.

3. Please be advised that Georgia and West, Inc. cannot guarantee timely review of requests for Bridge Supplier pre-approval after 4:00 p.m., local time, June 25, 2010.

The following clarifications are offered:

1. Asphalt paving requires a prime coat.
2. The GDOT Liquid Asphalt Index will not apply. No adjustment.
3. The Erosion Control 7 – day Inspection is an Owner expense. Re-inspections required by Contractor deficiencies are the Contractor's responsibility.
4. All stamped concrete shall require six (6) inches of GAB. Concrete sidewalks do not require GAB.
5. Changes in the Work, and Suspension of Work and Termination of Work shall be addressed as stipulated in Section 00080 of the General Conditions.

End of Addendum No. 3

Georgia and West, Inc.  
105 Corporate Drive  
Carrollton, GA 30117  
Phone: 770-834-4694  
Fax: 770-834-1005

E-mail: [mailbox@georgiaandwest.com](mailto:mailbox@georgiaandwest.com)