

Addendum 2, Solicitation No. 11-A007

**PERVIOUS CONCRETE PAVEMENT (Solicitation Nr 11-A007)**

The Carroll County Board of Commissioners submits Addendum 2 Solicitation No. 11-A007, **PERVIOUS CONCRETE PAVEMENT**. This addendum addresses questions /concerns directed to the County by prospective bidders.

Addendum 2 consists of clarifications, additions and/or revisions to the Contract Documents and is hereby made a part of those Contract Documents.

1. Proposals are still due 10:00 a.m., Thursday, March 17, 2011.
2. Pervious concrete mix design for bidding purposes shall be as follows:
  - Total cementitious material: 600 lbs. per cubic yard
  - Aggregate: 27 cubic feet
  - Water-cement ratio: 0.27 to 0.3All material used shall be per project specifications.
3. If the successful bidder is a Level I NRMCA installer, then the Owner will consider allowing the contractor to provide pervious concrete installation experience with references in lieu of test panel requirements. Previous experience must be a minimum of three (3) projects with scopes equal to or greater than that which is proposed for this project and must include references for each of the projects.
4. The Public Bid Opening will be at the County's Administrative Building, Room 501 located at 423 College Street, Carrollton, Georgia 30117 at 10:00 a.m., local time, on March 17, 2011.

All other Specifications, Terms and Conditions, not affected by the above changes and additions, remain in effect.

Bidders shall annotate receipt of this Addendum in their proposal. Proposals without this acknowledgement may be rejected.

R. Benedict  
Purchasing Manager  
(770) 830-5868  
[rbenedict@carrollcountyga.com](mailto:rbenedict@carrollcountyga.com)