

Addendum 4, Solicitation No. 11-A016

LITTLE TALLAPOOSA PARK PHASE I WATER AND SANITARY SEWER

The Carroll County Board of Commissioners submits Addendum 4 to Solicitation No. 11-A016, **LITTLE TALLAPOOSA PARK PHASE I WATER AND SANITARY SEWER**. Please read and review the attachment carefully.

CLARIFICATIONS, ADDITIONS AND REVISIONS

1. Proposals are still due 2:00 pm, Wednesday, May 25, 2011.
2. Please review the attached Addendum.
3. Project information may be obtained by contacting the Purchasing Department at 770-830-5868, email: rbenedict@carrollcountyga.com or by visiting the County's website at www.carrollcountyga.com/pages/purchasing.

All other Specifications, Terms and Conditions, not affected by the above changes and additions, remain in effect. Bidders shall acknowledge receipt of this addendum on the Bid Form in their bid packages. Proposals without this acknowledgement may be rejected.

R. Benedict
Purchasing Manager
(770) 830-5868
rbenedict@carrollcountyga.com

Addendum No. 4

Little Tallapoosa Park Phase 1
(Water and Sanitary Sewer)
Solicitation Number 11-A016
Carroll County Board of Commissioners

May 24, 2011

Addendum No. 4 consists of one (1) letter-size (8½" x 11") sheet.

Addendum No. 4 consists of clarifications, additions, and/or revisions to the Contract Documents and is hereby made a part of those Contract Documents.

1. Proposals are still due at 2:00 p.m., Wednesday, May 25, 2011.
2. The Septic System Installer will be required to install the electrical system for the pumps in the septic systems up to and including the control panel. The building electrician will make the connection to the power source. Testing requirements for the pumps will still be the responsibility of the Utility Contractor.

End of Addendum No. 4