



CARROLLTON • MARIETTA • GWINNETT

# Heath & Lineback Engineers, Inc.

## WEST GEORGIA OFFICE

209 CORPORATE DRIVE • SUITE 300 • CARROLLTON, GEORGIA 30117

(PH) 770.722.7631 • (FAX) 770.424.2907

EMAIL: badams@heath-lineback.com

April 28, 2010

---

### Request for Proposal for Cross Plains Hulett Road Bridge & Horsley Mill Road Bridge RFP# 2009040-044-T – Addendum #1

---

Dear Mr. or Mrs.:

Below are items considered Addendum #1 to the RFP issued on 4/14/10 for the referenced project. This addendum is being issued to clarify questions that have been received.

1. Section 4.3.A – Truss Style – The Top Chord is not required to be Arched. It may be Flat or Arched.
2. Section 4.9 – Truss Material – HSS sections are not required. Wide flange sections may be used in lieu of HSS sections.
3. Bottom Chord – Bottom Chord shall be designed and constructed to minimize the possibility of debris collection on the bottom chord. This shall be accomplished by the use of a double channel bottom chord.
4. Bid Bond – a bid bond will be required in an amount equal to 5% of the bid.
5. Bid Submittal Forms – each supplier shall provide their own bid forms for this bid. Each bridge shall be bid as a separate line item in the bid, however both bridges will be awarded to one supplier.

The proponent must sign this Addendum below stating that it was received and the signed copy shall be submitted with the proposal.

Sincerely,

---

Brian K. Adams, P.E., S.E.

cc: Charles Pope, Director of Public Works and Solid Waste, Carroll County, Georgia  
Russ Benedict, Purchasing Director, Carroll County, Georgia

Addendum #1 has been received and accepted:

---

Authorized Representative of Proponent

CORPORATE OFFICE

2390 CANTON ROAD • MARIETTA, GEORGIA 30066

770.424.1668 • (FAX) 770.424.2907 • e-mail: hle@heath-lineback.com

[WWW.HEATH-LINEBACK.COM](http://WWW.HEATH-LINEBACK.COM)